


# Finding the serial number


For technical enquiries and spare parts orders for your Teddington air curtain system, we require the six-digit serial number of your unit. Please have this to hand when contacting us.

If you have a Teddington control unit with a touchscreen display, you can easily retrieve the serial number from the control unit. Otherwise, you will find it on the type plate on the unit (see page 2).


## TCX/TCX-E control unit:



Tap the Info icon on the TCX control panel.




Then tap the 'Info Control' icon.




You will then be shown the six-digit serial number.

## TLC 700 control unit:



Tap the cog icon to open the settings menu.




Then tap the 'info icon' – a person with a question mark.




The six-digit serial number will then be displayed in the overview.


## TMC 300 / 300 E / 500:








Tap the cog icon at the bottom to open the Settings menu.




Then tap the info icon.




You will then be shown the six-digit serial number.

-  Wear protective goggles when opening the air curtain or during filter maintenance work to avoid dirt or dust particles from inside the air curtain getting into your eyes.
-  Fan motors take approximately 3 minutes to stop rotating before the air curtain may be opened. Otherwise there is a risk of getting caught in the rotating fans or of injury to hands.
-  The inspection cover is not secured by a chain or similar device. Please open carefully and slowly after unlocking.
-  Warning of risk of burns due to hot surfaces!
-  Warning of injury to the hands by crushing or cuts resulting from sharp edges!


**Case 1: Shop & Business air curtain with a turnbuckle:**



Use a screwdriver or a coin to turn the turnbuckle 90° and open the filter flap.




Behind this, depending on the length, you will find 2–3 Phillips-head screws, which need to be removed.




Open the access panel. The serial number (AB No.) can be found on the circuit diagram inside the panel.


**Case 2: Shop & Business air curtain with hexagonal fastening**



Use a size 6 Allen key to open the locking screws.




Open the access panel.




You will find the serial number (AB No.) on the circuit diagram inside the cover.


**Case 3: Shop & Business air curtain with pin hinge**



There is a pin hinge at each end behind the filter flap. Press them to unlock the flap.




Behind this, depending on the length, you will find 2–3 Phillips-head screws, which need to be removed.



You can then open the access panel. The serial number (AB No.) can be found on the circuit diagram inside the panel.


**Case 4: Industrial air curtain**



**Ratiovent, Robuvent:** At the corner of the housing on the fan side



**Induvent:** Next to one of the external terminal boxes



**Friguvent:** On the side of the terminal box